




# Test Report Summary

Product Information	
Licence Number:	215527
Licensee:	UPONOR SA
Product Identification	Uponor Smatrix WAVE Plus
Test Specifications	
Tested Application:	Water Floor Heating Systems
Temperature Sensor	
- Type:	NTC Thermistor
- Time Constant:	4 Mins
Actuator Identification	VARIO PLUS ACTUATOR PRO NC MT 30X1,5 24V (1000138)
- Type:	Stroke Actuator: thermal 0-10V
Valve Identification	UPONOR VARIO PLUS MANIFOLD FLOWMETER
- Characteristic	FM Globe valve: linear
Fan Speed (For Fan Coil Applications)	
- Characteristic	None
Test Result	
Temperature Control Accuracy $C_A$ according EN 15500	0.4

**11 December 2015**  
**Brussels**

  
Managing Director Dr. Peter Hug  
**eu.bac**