




Test Report Summary

| Product Information | |
|--|---|
| Licence Number: | 215502 |
| Licensee: | UPONOR SA |
| Product Identification | Uponor Smatrix WAVE |
| | |
| Test Specifications | |
| Tested Application: | Water Floor Heating Systems |
| Temperature Sensor | |
| - Type: | NTC Thermistor |
| - Time Constant: | 4 Mins |
| Actuator Identification | VARIO PLUS ACTUATOR PRO NC MT 30X1,5 24V (1000138) |
| - Type: | Stroke Actuator: thermal 0-10V |
| Valve Identification | UPONOR VARIO PLUS MANIFOLD FLOWMETER |
| - Characteristic | FM Globe valve: linear |
| Fan Speed (For Fan Coil Applications) | |
| - Characteristic | None |
| Test Result | |
| Temperature Control Accuracy C_A according EN 15500 | 0.4 |

11 December 2015
Brussels


Managing Director Dr. Peter Hug
eu.bac